

Nepal Electricity Authority
 (An Undertaking of Government of Nepal)
Transmission Directorate
Grid Development Department
Dordi Corridor 132 kV Transmission Line Project

Design, Supply, Construction, Testing and Commissioning of Kirtipur 132/11 kV Substation (ICB No: DCTL-073/74-02)

Clarification No. 1

6		Drawings	Layout plan of switchyard	The dimensions are not shown in the layout plan of the switchyard. Kindly provide a clearer drawing to allow us to quote accordingly.	The drawings furnished by the Employer with the bidding document are preliminary and indicative only and the bidder shall investigate the site and design as per actual site requirement. However for tender purpose, bidder may refer to drawing provided for sectional views of outdoor equipments which shows dimensions clearly.
7	Price Schedule	Volume III	48 V DC Battery Capacity	As per price schedule, the 48 V battery has 200 AH requirement. But as per technical specification the 48 V battery is 100 AH. Please clarify the requirement.	Please refer to Addendum No. 3
8		Volume II	Technical Specification	The technical specification of testing equipment is not available. Please provide the same to enable us to quote accordingly.	The technical specification with scope of testing equipments including special tools and tackles shall be decided during detail engineering. Bidders are requested to quote their price considering the nature of work based upon the given system parameters.
9		Volume I	Functional Guarantee Form	The technical proposal requires for a Functional Guarantee Form. But the format for the same has not been provided. Request you to clarify the same.	Please refer to Addendum No. 3





Nepal Electricity Authority
 (An Undertaking of Government of Nepal)
Transmission Directorate
Grid Development Department
Dordi Corridor 132 kV Transmission Line Project

Design, Supply, Construction, Testing and Commissioning of Kirtipur 132/11 kV Substation (ICB No: DCTL-073/74-02)

Clarification No. 1

S. No.	PAGE No.	CLAUSE No.	REFERENCE	DESCRIPTION	BIDDER QUERIES AND COMMENTS	NEA CLARIFICATION
1	1-27	ITB 44.1(i)	Section 1 – Instruction to Bidders	If bid price of the bidder selected for acceptance is up to 15 (fifteen) percent below the approved cost estimate, the performance security amount shall be 5 (five) percent of the bid price.	Request you to please inform the estimated cost of the project and please clarify if quoted bid price is higher than approved cost estimate, then what will be the percentage for performance security BG.	The provision in respective clause shall remain unaltered.
2	9-7	Appendix 1 – Terms and Procedures of Payment	Section 9 – Contract Forms		Request you to please clarify whether 10% advance payment is interest free or interest bearing. If interest bearing, please clarify percentage of interest.	10% advance payment against receipt of an irrevocable advance payment security for equivalent amount made out in favor of Employer which shall be interest free.
3					Looking at the complex nature of job it is very difficult for us to complete the optimized design for the complete switchyard within the stipulated time. Request you to extend the submission date to 26.07.2017.	It has not been decided yet however will be notified to bidder if there is any extension.
4	3-7	Chapter 11: Power and Control Cables	Volume II	Technical Specification of 11 kV cable	Technical Specification of 11 kV cable is not available. Kindly provide the same.	Please refer to Addendum No. 3. Also, required technical particular of 11 kV Power Cable is given in Clause 23.11.4 of Chapter 23: Technical Data Sheet of Volume II of Bidding Document.
5		Price Schedule	Volume II	11 kV indoor switchgear system	For the 11 kV indoor switchgear system, is control and relay panel required? Please clarify.	Yes, it is required. Please refer to Chapter 15: 11 kV Indoor Switchgear of Volume II for Technical Specifications. Correspondingly, refer to S. No. 7.0 of Price Schedule in Volume III to quote the price accordingly.

