

Nepal Electricity Authority
Grid Substation Automation Project Phase 2

Clarification No: 04

OCB No and Title : Tender No: PMD/EGMP/GSAPP2-78/79-01 (Procurement of Plant for Design, Supply, Installation, Integration, Testing and Commissioning of Substation Automation System (SAS) for Existing Grid Substations of six-grid division office across Nepal.)

S.N	Volume/Section	Clause no.	Clause Description	Clarification Required	NEA Response
1	Vol-3	Volume- 3: Schedule No : .1	VOIP telephone instrument with one common POE+ switch (number of ports as per requirement)	VOIP technical specification requirement is not clear.	As per Vol-2, Chapter-1 , the bidder shall establish hot line communication with each individual s/s under respective MCC through VOIP. i.e bidder shall supply the related telephone sets, switches, hardwares and softwares to connect MCC to its respective substations(including spare sets and ports for future number of substations as specified) to communicate through the fibre channel connecting the substations. No local or STD/ISD calls are envisaged through this line



[Handwritten Signature]