

Contract Award Notification

Project Name: Nepal Distribution System Upgrade and Expansion Project (AIIB)

Country: Nepal

Project Number: L0086A-NPL

Contract Reference No: ICB-DCSD-2078/79-DSUEP-AIIB-W4

Scope of Contract: Procurement of material, equipment, associated accessories and necessary installation services including design, erection, testing, and commissioning of 33/11 kV Substations and 33 kV, 11 kV, 400 V Lines and Distribution System Network in Rukum West, Jajarkot, and Kalikot districts of Nepal (Package No. W4)

Duration of Contract: 730 days

Awarded Tenderer				
Name of the Firm	Address	Tender Price at Opening	Evaluated Tender Price	Ranking
CEPL-SPR-TUNDI JV	Shantibasti, Sanepa-03, Ring Road, Lalitpur, Nepal	USD 15,418,168.09 + NPR 1,031,224,311.58	USD 15,418,490.37 + NPR 1,031,224,887.14 (excluding Custom duty and VAT)	I

Evaluated Tenderer(s)				
Name of the Firm	Address	Tender Price at Opening	Evaluated Tender Price	Ranking
Angelique International Limited	104-107 Hemkunt Tower, 1 st Floor, 98 Nehru Place, New Delhi - 110019, India	USD 16,136,219.38 + NPR 1,107,152,576.60	USD 16,136,189.04 + NPR 1,107,163,076.71	II
Samanantar-Jaya Durge- Capital JV	KMC-09, Old Baneshwor, KTM, Nepal	USD 20,501,490.49 + NPR 631,048,689.26	USD 20,429,707.14 + NPR 628,844,683.36	III
CEPL-SPR-TUNDI JV	Shantibasti, Sanepa-03, Ring Road, Lalitpur, Nepal	USD 15,418,168.09 + NPR 1,031,224,311.58	USD 15,418,490.37 + NPR 1,031,224,887.14	I

Rejected/Non-responsive Tenderer(s)		
Name of the Firm	Address	Reason(s) for Rejection
SOCOL Corporation Limited	No3799 Dongnanhu Road, Jingkai District, Changchun City, Jilin Province, China	i. The proposed functional guarantee losses (both No-load loss and load loss) of all single phase distribution transformers and station transformers exceed the prescribed value as mentioned in the technical specification (and hence non-responsive in accordance with ITT 34.1). ii. Manufacturer of Some of the major equipment do not fulfill the NEA requirement (and hence non-responsive in accordance with ITT 35.4).

