

Lekhnath Damauli 220 kV Transmission Line Project
Package B: Substations / Re-tender
BMZ201667773/KfW508598

Amendment No 2
September 10, 2024

No	Reference	Amendment				
1.	Part 2 VII-8 Data Sheets 3.1.27	<p>For Item 3.1.27 Type of enclosure (bus bar/feeder), the Data Required shall be updated to read as follows:</p> <table border="1" data-bbox="522 632 1312 793"> <tr> <td data-bbox="522 632 631 793">3.1.27</td> <td data-bbox="631 632 915 793">Type of enclosure (bus bar /feeder)</td> <td data-bbox="915 632 1005 793" style="text-align: center;">-</td> <td data-bbox="1005 632 1312 793">3-phase* or 1 phase / 1-phase (* busbar to be segregated from active parts by gas barrier)</td> </tr> </table>	3.1.27	Type of enclosure (bus bar /feeder)	-	3-phase* or 1 phase / 1-phase (* busbar to be segregated from active parts by gas barrier)
3.1.27	Type of enclosure (bus bar /feeder)	-	3-phase* or 1 phase / 1-phase (* busbar to be segregated from active parts by gas barrier)			
2.	Part I Bidding Procedures Section II Bid Data Sheet ITB 23.1	<p>First paragraph of ITB 23.1 shall be read as follows:</p> <p style="text-align: center;">The Bid shall be submitted not later than Date: 7 October 2024 Time: 12:00 noon (Nepal Time)</p>				
3.	Part I Bidding Procedures Section II Bid Data Sheet ITB 26.1	<p>Last paragraph of ITB 26.1 shall be read as follows:</p> <p style="text-align: center;">Date: 7 October 2024 Time: 14:00 hour (Nepal Time)</p>				